

Power Curve Inc.

Arkansas State University Searcy Campus.

HVAC Dept. Mr. Joe Newnum (501) 207-1642

Installed XP-AC in Trane AC units in the business department

Unit size	Current w/o XPAC 9/9/09	1 hour After installing XPAC	24 Hours after installing XPAC	5/11/2010	8/09/2010 1 year after installing XPAC
1 – 2 ton heat pump	9.1 amps	8.6 amps	8.6	7.4	7.5
2 – 3 ton heat pump	14 amps	13.6 amps	13.1	9.6	10.2
3 – 2 ton heat pump	9.6 amps	9 amps	9	8.3	8.2
4 – 5 ton heat pump	19.6 amps	19 amps	19	14.5	13.75
5 – 4 ton heat pump	14.6 amps	14.1 amps	14.1	11.4	9.3